



Department of Transportation  
Bureau of Construction and Materials

Materials and Research Center  
2300S.W. Van Buren Street  
Topeka, KS 66611-1195

Richard Carlson, Secretary  
Greg M. Schieber, P.E., Chief

Phone: 785-296-2231  
Fax: 785-296-2526  
Hearing Impaired - 711  
kdot#publicinfo@ks.gov  
<http://www.ksdot.org>

Sam Brownback, Governor

August 23, 2017

Renee Thomas  
Adhesives Technology Corp.  
450 E. Copans Rd.  
Pompano Beach, FL 33064

Dear Ms. Thomas,

We have evaluated your Crackbond LR-321 submittal. The product is substantially compliant with the requirements for Types I, II, IV, and V, Grade 1, Class C bonding systems of Section 1705 of the 2015 KDOT Standard Specifications. The substantially compliant statement is because the gel time of 27 minutes is close to the minimum required 30 minutes. Here is a summary of the approval:

<u>Product</u>	<u>Type</u>	<u>Grade</u>	<u>Class</u>
Crackbond LR-321	I	1	C
	II	1	C
	IV	1	C
	V	1	C

This product will be placed on the KDOT prequalified list PQL 10.5, "Epoxy-Resin-Base Bonding Systems for Concrete."

Please direct any questions to me at 785-368-6521.

Sincerely,

Richard Barezinsky, P.E.  
Assistant Bureau Chief-Materials