

Materials and Research Center
2300S.W. Van Buren Street
Topeka, KS 66611-1195

Richard Carlson, Secretary
Greg M. Schieber, P.E., Chief



Phone: 785-296-2231
Fax: 785-296-2526
Hearing Impaired - 711
kdot#publicinfo@ks.gov
<http://www.ksdot.org>
Sam Brownback, Governor

August 23, 2017

Renee Thomas
Adhesives Technology Corp.
450 E. Copans Rd.
Pompano Beach, FL 33064

Dear Ms. Thomas,


We have evaluated your Ultrabond 2100 submittal. The product is compliant with the requirements for Types I, and II, Grade 2, Class C bonding systems of Section 1705 of the 2015 KDOT Standard Specifications. Here is a summary of the approval:

<u>Product</u>	<u>Type</u>	<u>Grade</u>	<u>Class</u>
Ultrabond 2100	I	2	C
	II	2	C

This product will be placed on the KDOT prequalified list PQL 10.5, "Epoxy-Resin-Base Bonding Systems for Concrete."

Please direct any questions to me at 785-368-6521.

Sincerely,



Richard Barezinsky, P.E.
Assistant Bureau Chief-Materials