



Department of Transportation
Bureau of Construction and Materials

Phone: 785-296-2231
Fax: 785-296-2526
Hearing Impaired - 711
kdot#publicinfo@ks.gov
<http://www.ksdot.org>

Materials and Research Center
2300S.W. Van Buren Street
Topeka, KS 66611-1195

Richard Carlson, Secretary
Greg M. Schieber, P.E., Chief

Sam Brownback, Governor

August 28, 2017

Renee Thomas
Adhesives Technology Corp.
450 E. Copans Rd.
Pompano Beach, FL 33064

Dear Ms. Thomas,

We have evaluated your Ultrabond 1 submittal. The product is compliant with the requirements for Types II and V, Grade 3, Class A and Types I and IV, Grade 3, Class A, B and C bonding systems of Section 1705 of the 2015 KDOT Standard Specifications. Types I and IV, Grade 3 Class B and C requires automatic proportioning, mixing, and dispensing equipment. Here is a summary of the approval:

<u>Product</u>	<u>Type</u>	<u>Grade</u>	<u>Class</u>
Ultrabond 1	I	3	A, B*, C*
	II	3	A
	IV	3	A, B*, C*
	V	3	A

*Only Qualified if Automatic proportioning, mixing and dispensing equipment is used.

This product will be placed on the KDOT prequalified list PQL 10.5, "Epoxy-Resin-Base Bonding Systems for Concrete."

Please direct any questions to me at 785-368-6521.

Sincerely,

Richard Barezinsky, P.E.
Assistant Bureau Chief-Materials