



**Department of
Transportation**
transportation.ohio.gov

Mike DeWine, Governor
Jim Tressel, Lt. Governor
Pamela Boratyn, Director

July 7, 2026

Renee Thomas
Sr. Regulatory Engineer & DOT Mgr.
Adhesives Technology Corp.
450 E. Copans Rd.
Pompano Beach, FL 33064

Subject: ULTRABOND 1

Dear Renee,

The Office of Materials Management is writing to inform you that ULTRABOND 1 has been approved and added to the Qualified Products List (QPL). The product meets the requirements of Item 705.20 Non-Shrink, Non-Metallic Materials and conforms to ASTM C881, Type IV, Grade 3, Class B & C. The application temperature is listed between 40 - 110 ° F. Approved application systems are limited to a Cartridge Nozzle System or a Pumping Metered System. Please be mindful of the annual recertification requirements and the Department specifications with regards to the product moving forward.

The QPL list is available at the link below:

[Qualified Products List](#)

Note: To locate the item, select item 705.20 from the drop-down list and click View Report.

If you have any questions or concerns, please reach out to me at Mohamed.Salim@dot.ohio.gov , or at (614) 752-6997.

Regards,

Daniel Miller, P.E.
Administrator

Mohamed Salim, M.S.E., E.I.
Transportation Engineer
ODOT Office of Materials Management
Cement & Concrete Section

1600 W. Broad Street, Columbus, Ohio 43223

D: 614.752.6997 C: 614.965.2849

Mohamed.Salim@dot.ohio.gov

1980 West Broad Street
Columbus, OH 43223 U.S.A.

614 | 466 7170
transportation.ohio.gov